



Product Service

Attestation of Conformity

No. N8A 125663 0002 Rev. 00

Holder of Attestation: Suzhou Gongyuan Automation Technology Co., Ltd.

118 Fuchunjiang Dong Lu
215506 Changshu City, Jiangsu Province
PEOPLE'S REPUBLIC OF CHINA

Product: Electronic measuring equipment
(Insulation monitoring devices for IT systems)

Model(s): GYIM-DAR

Parameters:

Type of system to be monitored:	DC IMD
nominal voltage U_n :	1000VDC
rated supply voltage U_S :	10-30VDC
Rated power:	$\leq 1.5W$
Specified response value R_{an} :	1k Ω ~1M Ω
System leakage capacitances C_e :	1 μF
IP protection class:	IP00

Tested according to: EN 61557-1:2007
EN 61557-8:2015

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2014/35/EU relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for conformity assessment. For details see: www.tuvsud.com/ps-cert

Test report no.: 64105233187101

Date, 2024-05-24


(Kevin Liu)

Page 1 of 1

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.